DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 4736596661
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Alice May
ADDRESS: 2635 S. Chipley Ford Rd.
PROPOSED FACILITY: 3BR Repair
LOCATION OF SITE: 2635 S Chipley Ford Rd.
WATER SUPPLY: • Private • Public • Well • Spring • Other N/A
EVALUATION METHOD: • Auger Boring • Pit • Cut

APPLICATION DATE: 10-24-13
DATE EVALUATED: 10-28-13
PROPERTY SIZE: .47 acres
PROPERTY RECORDED: Yes

TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	3,5% L	0-6	SCL SBK	F Mod SC	+48"	+48"	+48"	+48"	PS 0.3
		6-24	C mica SBK	F Mod SC					
		24-48	CL mica WSBK	F Mod SC					
2	3% L	0-5	SCL SBK	F Mod SC	+48"	+48"	+48"	+48"	P 0.3
		5-22	C mica SBK	F Mod SC					
		22-48	CL mica WSBK	F Mod SC					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		PS
System Type(s)		III
Site LTAR		0.3

OTHER FACTORS (.1946): N/A
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Justin Henderson
OTHER(S) PRESENT: N/A

COMMENTS: N/A