## IREDELL COUNTY HEALTH DEPARTMENT

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles Nantz III DATE 8-12-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Ft. Dobbs Rd #1930 off Rd N/W of Ft Dobbs Historical Site

S. R. No. 1930


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes (✓) | No ( ) | Character & Porosity of Soil | Cecil Clay | |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | 1 | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | Slope to back | |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | 24"+ | |
| | | | Rock or other impervious formations | None | |

Lot Area 1¼ acre




Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 250 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Yoke Septic Tank Service

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 8/12/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold