DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

640 -140 1920 Ft 640 Ft

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

480 Ft - 25% Rob.

OWNER: Tony & Tracy Lollie
ADDRESS: 145 Rose Lea Lane
PROPOSED FACILITY: 4BR House w Basement
LOCATION OF SITE: Rumley
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

APPLICANT: Todd Ellis Bailey Lewis
APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
PROPERTY RECORDED: _____

Fort Dobbs Farm Lot #25

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	10% Linear	0-9	SiCl2 vwsbk	fr SS SP SEXP					PS -25
		9+17	cl2 wsbk	fr ss sp SEXP					
		17-36	c sbk	fi s p SEXP					
		36-48	c sbk	fi ss p SEXP					
2	6% Linear	0-9	scl/cl wsbk	fr SS SP SEXP					PS -25
		9-38	C sbk	fi s p SEXP					
		38-48	c some mica clay	fi s p SEXP					
3	9% Linear	0-10	scl wsbk	fr SEXP					PS .25
		10-36	C sbk	Fi SEXP					
		36-48	C some mica	Fi SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25% Reduction	50% Reduction
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____