HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT:  OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
Chris Goss PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	Linear & Nose Slope 15%	0 to 4"	L	GR		.1942 WETNES CONDITION	N/A
		4 to 20	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		20 to 30	Transition			.1944 RESTRICTIVE HORIZON	N/A
		30"	Saprolite		Sandy loam	.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.14
2	Linear & Nose Slope 15%	0 to 4"	L	GR		.1942 WETNES CONDITION	N/A
		4 to 25	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		25 to 42	B/C			.1944 RESTRICTIVE HORIZON	N/A
		42	Saprolite			.1948 PROFILE CLASSIFICATION	PS
					Sandy loam	PROFILE LTAR	.13
3	Linear 18%	0 to 4"	L	GR		.1942 WETNESS CONDITION	N/A
		4 to 18	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		18 to 25	Transition			.1944 RESTRICTIVE HORIZON	N/A
		25+	Saprolite			.1948 PROFILE CLASSIFICATION	PS
					Sandy loam	PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946): SYSTEM TYPE Conv. Gravity
EVALUATED BY: R. C. Moore OTHER(S) PRESENT: Kenneth McCann
COMMENTS:

DRAFT

0 0 3 8 7