IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mahaffey Bldg Co. DATE 3-5-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Quigley Ford Rd TR. on Rt #1924 Home on left S. R. No. 1924


SUBDIVISION NAME Clearview Acres LOT NO. 3 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil		apcy
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate		mpi-60
Auto. Wash. Machine	Yes (✓)	No ( )	Topography		Slopes to front
Site Suitable	Yes (✓)	No ( )	Depth to Water Table		30+
			Rock or other impervious formations		None

Lot Area 100 x 200



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Harlan Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Front yard should be landscaped To have ample cover over Nitrification field

CERTIFICATE OF COMPLETION BY Glenn Ford Jr. DATE 2/5/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold