IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. Builders Inc. DATE 8-5-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chipley Ford Rd - 2nd house on Rt. past Rd # 1924

S. R. No. 1924


SUBDIVISION NAME Chipley Park LOT NO. 127 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	CnB2 - (Red Clay)	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate		
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Front	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25'+	
			Rock or other impervious formations	none	

Lot Area _____



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros. Builders

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 8/5/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold