IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Poole → Hope Brothers DATE 11-16-78 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Chipley Foard Rd TR on Nixon Rd 200' on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Fine Sandy clay loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	80 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area ½ acre			Rock or other impervious formations	none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field: Alter

No. of Lines 1

Sq. Ft. 300 Linear Ft. 100

Depth of Stone in Lines 10"

Water Supply: Individual ( ) Public (✓)

Installed by Hope Brothers

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Pipe all downspouts & Grade to where all surface water goes around system.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 11-16-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold