IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 121399 PIN# 4736718251 704-299-9301 DATE 7-2-08

OWNER OR APPLICANT Bobby Stewart PHONE: Business 704-872-5773 Home 704-883-9200

ADDRESS 312 SEVEN SPRINGS LOOP Statesville NC 28625

LOCATION 21 [redacted] NORTH (L) FORT DOBBS RD (R) CEDAR LANE DRIVE ON RT

SUBDIVISION DOBBS VALLEY BLOCK / SECTION II LOT 38 LOT AREA 2.159 AC SITE CLASS. PS DESIGN FLOW 600 L.T.A.R. .35

Septic Tank: 1500 Gallons; STB 900 Date 6-15-09
Pump Tank: _____ Gallons; PT _____ Date _____
Pump Make: _____ Model _____ Serial No. _____
Nitrification Field: No Fields 1 Square Feet 1714 Linear Feet 428
No Lines 4x107' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI
System Description: GRAVITY 25% REDUCTION
Repair System Description: SAME
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 5 No. Persons 10 No. Employees ____

Water Supply: ☐ Individual ☒ Public ☐ Community

☒ Gravity ☐ Pressure ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions:
(1) Septic Lines MUST BE INSTALLED AT 36" TRENCH BOTTOM (2) MAINTAIN SETBACKS (3) BASEMENT DIG AT TIME OF LO

Comments/Conditions:
Red Tag Tile
Septic Marker

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGN BY LORNE COOK, P.S.

AS BUILT SKETCH

End CAP distribution

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Bobby Stewart date 7/3/08 Installed by: A-1 Backhoe

Improvement Permit by: _____ date 7/2/08 Operation Permit by: Lorne Cook date 10-23-09

Authorization to Construct by: _____, R.S. date 7/3/08 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

Permit # 121399

Pin # 4736718251

1"=50'

