DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH, ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH

Sheet 1 of 1
PROPERTY ID #: 4736 7324 006
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM
(Complete all fields in full)

OWNER: Kenny Nicholson
ADDRESS: 231 Clearview Rd
PROPOSED FACILITY: SFD
PROPOSED DESIGN FLOW (.1949): 240
LOCATION OF SITE: Chipley Ford to Clearview lot on Right
APPLICATION DATE: 07/01/14
DATE EVALUATED: 07/16/14
PROPERTY SIZE: 1ac
PROPERTY RECORDED: Yes
WATER SUPPLY: ☒ Private ☒ Public ☐ Well ☐ Spring ☐ Other N/A
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 6%	0-12	C fi	SBk SE	PS	PS	N/A	N/A	PS .3
		12-43	Bt fi/f	w/Bk SE					
		43-48	Saprol fi	mass w/Bk					
2	L 10%	0-28	C fi	SBk SE	PS	PS	N/A	N/A	PS .3
		28-48	Bt fi/f	w/Bk SE					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	—
System Type(s)	25%	—
Site LTAR	.3	—

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: H. Snow
OTHER(S) PRESENT:

COMMENTS: