DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jack Borders APPLICANT: Jack Borders
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 2/22/01
PROPOSED FACILITY: 3BR Home/Crawl PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .43 Ac
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut 3B
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot #25

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	Linear 2%	0-12	L						PS .35
		12-21	SCL						
		21-36	CL						
		36-48	SC						
2	Linear 2%	0-14	L		28" Restrictive mottles				PS .3
		14-28	SCL						
		28-48	CL w Many Fine	.35					
3	Linear 2% Rock	0-7	SCL						PS .4
		7-12	SCL						
		12-48	Sap SL						
4	Linear 2%	0-9	SCL						PS .35
		9-28	L						
		28-32	SCL Few Fine						
		32-48	SCL Few Fine						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25% Reduction Trench	53% Reduction Trench
Site LTAR	.3	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____