PERMIT #168458 20

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Norman Creed Moore DATE 5-11-76 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Hwy 115 N. T.R. on Rd 1910 at Bruce Moore Farm
Trailer on L. About ½ Mile S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 5 Acres

Character & Porosity of Soil Cecil Clay
Percolation Rate —
Topography Slope to Highway
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3 275
Sq. Ft. 690 Linear Ft. ~~690~~
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Raymond Adams

Location of the proposed SUN ROOM addition does not appear to impact the existing on-site septic system.**NOTE:

R. STEVE HEDRICK REHS
Date: 9-6-2011
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. G. Stutzenson DATE 5-11-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold