IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

8670
OWNER OR CONTRACTOR Dave McIntyre DATE 9-28-88 PERMIT NO. 610

PHONE: Business _____ Home _____

LOCATION 115 N TR close Rd Mile on Right

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 58 SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	prev suitable	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	4	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Flat to G.S.	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	5'+	
			Rock or other impervious formations	None	

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12

Water Supply: Individual ( )
Public (✓)

Installed by Al Backhoe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY D Weaver

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D Weaver DATE 2-22-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold