DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: Bladen

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4737454897

OWNER: Andy Gibson APPLICANT: William Gibson
ADDRESS: 2982 S Chipley Ford APPLICATION DATE: ____ DATE EVALUATED: 12-18-00
PROPOSED FACILITY: 3BR S/W Mfg PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 86.77 Acres
LOCATION OF SITE: 2982 S. Chipley Ford Rd PROPERTY RECORDED: ____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	SLIGHT N 10%	0-28	SBK C	FI SEXP					PS 0.3
		28-36	SBK SAP CL	FR SEXP					
		36-48	GR SAP CL	VFR SEXP					
2	SLIGHT N 10%	0-30	SBK C	FI SEXP					PS 0.3
		30-38	SBK SAP CL	FR SEXP					
		38-48	GR SAP CL	VFR SEXP					
3	SLIGHT N 8%	0-30	SBK C	FI SEXP					PS 0.3
		30-36	SBK SAP CL	FR SEXP					
		36-48	GR SAP CL	VFR SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): None
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. Hardwick
OTHER(S) PRESENT: ____