IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Pratt DATE 1-30-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chipley Ford Rd. #1907 Pratt St.

S. R. No. _____


SUBDIVISION NAME Brinkley Acres LOT NO. 9 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Coil	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	2 min	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Unk	
			Rock or other impervious formations	none	

Lot Area _____



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by John Septic Tank Service

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox DATE 1/30/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold