IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Blake Pratt DATE 3-18-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chipley Ford Rd. Pratt Tract

S. R. No. _____

SUBDIVISION NAME Pressley Acres LOT NO. 15 SECTION OR BLOCK NO. A

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20,000 Sq ft.


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Slope

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Robert Hoke

R.E. Fox

IMPROVEMENTS PERMIT BY W. M. Howard

COMMENTS: Downspouts should be diverted

Away from Tank & lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3-18-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold