IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Flake Pratt DATE 4-24-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Presley Acres Lot #22

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. 22 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,000 sq ft +


Character & Porosity of Soil Red Clay

Percolation Rate 24

Topography Slight Slope to Rt.

Depth to Water Table 2'

Rock or other impervious formations None



Plot of System

Size of Tank 1,000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Robert Hoke

R.E. Fox

IMPROVEMENTS PERMIT BY William M. Howard

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M. Howard DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold