IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mike Pratt DATE 18 June 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Cloffy Ford Rd & Purdy Acres

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. #16 SECTION OR BLOCK NO. A

House ✓ Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 20,000

Character & Porosity of Soil Red Clay
Percolation Rate fine
Topography Slope to road and left of house
Depth to Water Table —
Rock or other impervious formations —



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 18 in
Water Supply: Individual ( )
Public ✓

Installed by Mike Pratt
Lot Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Mike Pratt DATE 18 June 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold