IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hobe Pratt DATE 25 July 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chipley Ford to Lumley Acres. Rock St. Next to last house on left.

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. # 19 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20,000 plus


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Slope & [illegible]

Depth to Water Table [illegible]

Rock or other impervious formations [illegible]



Plot of System Rock St.

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Robert Hobbs - Owner

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M Howard DATE 25 July 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold