DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dixieland Inc. APPLICATION DATE 22 Jan 09
ADDRESS: 133 Redemption Rd Statesville DATE EVALUATED: ___
PROPOSED FACILITY: 3BR Home PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: 1.349 ac.
LOCATION OF SITE: Chipley Rd Twin Bluegill - T2 Homewood Cr on LT. PROPERTY RECORDED: ___
WATER SUPPLY: • Private • ✓ Public • Well • Spring • Other ___
EVALUATION METHOD: • ✓ Auger Boring • Pit • Cut TYPE OF WASTEWATER: • ✓ Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 0%	0-20	wSBK/SiCl	VFr/sspl	>48	>48	-	-	PS 0.3
		20-48+	SBK/SiC	Fr/sspl					
2	L 0%	0-18	wSBK/SiCl	VFr/sspl	>48	>48	-	-	PS 0.3
		18-48+	SBK/SiC	Fr-Fi/sspl					
3	L 6%	0-23	wSBK/SiCl	Fr/sspl	>48	>48	-	-	PS 0.3
		23-48+	SBK/SiC	Fr-Fi/sspl					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Tim Higgins, R.S.
OTHER(S) PRESENT: ___

COMMENTS: ___