DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6/17/97
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 24 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger-Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (1941) STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	R-L 4%	0-36	sabk rc/cl	fr sp-sss p sep					PS .3 @ 364
		36-48	wk sbk RCL w/ mod sap & wr						
2	SS Rolling somewhat complex 4-8%	0-19	ns sbk R c/cl	fr sp-sss p sep	gravelly				PS .34
		19-48	wk sbk R sl cl	fr sss p sep					
3	SS 6-10%	0-10	sbk R c/cl	fr sss p sep		(46)			
		10-20	gr sl sap	fr					
		20-23	hard fract rock						
		23-55	gr-stless sl sap/wr mica						
4	end of pit	0-36	A-wk sbk R cl w/ mod sap/wr						
		36-48+	sap/wr mica	ss-ns np					
			appears to be wk sbk sap						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

Lot 4 ST CRC WAD 5/16 5-17-97 1066 CAP:

000357