IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Leonard Bailey DATE 11-10-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N across S. Yadkin River - T.R. on Rd #1905 (Cowles Dairy Rd) - Go approx 1 mile House on R. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area Approx 2 Acres


Character & Porosity of Soil Cecil Clay

Percolation Rate _____

Topography Slope to front

Depth to Water Table Low

Rock or other impervious formations None



Plot of System #1905

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY Mike Howard

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11-10-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold