SHEET 1 OF 1

DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: 13E-1-A57
DATE: DEC. 7, 1995
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: TOM BEATTY
ADDRESS: BOX 1019
STATESVILLE, N.C. 28677

OWNER X AGENT: PHONE: 872-9511
APPLICATION DATE: 11-22-95 DATE EVALUATED 12-7-95
PROPOSED FACILITY: HOUSE
PROPERTY SIZE: 115' X 184'

LOCATION OF SITE: RIVER RUN TR LOT #51
WATER SUPPLY: On-site Well X Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring X Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	NS	0-12	SCL	1, SBK	1:1			.1942 Wetness Cond. - 0
	6-8%	12-48	CL	1, SBK	1:1			.1943 Depth/.1956 Sapr. - 48"
								.1944 Restrictive Hori. - 0
								.1948 Profile Class. - P.S.
								Profile LTAR - .3
2	NS	0-12	SCL	1, SBK	1:1			.1942 Wetness Cond. - 0
	6-8%	12-48	CL	1, SBK	1:1			.1943 Depth/.1956 Sapr. - 48"
								.1944 Restrictive Hori. - 0
								.1948 Profile Class. - P.S.
								Profile LTAR - 0.3
3	L							.1942 Wetness Cond. - 0
	8-10%	0-18	SCL	1, SBK	1:1			.1943 Depth/.1956 Sapr. 0/40"
		18-40	C	1, SBK	1:1			.1944 Restrictive Hori. - 0 40"
		40-48	SAP	C				.1948 Profile Class. - P.S.
								Profile LTAR - 0.3
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) O.K. OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) P.S.

SYSTEM TYPE CHAMBER GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.3

EVALUATED BY: Bradley Stallard OTHER(S) PRESENT: STEVE HEDRICK

COMMENTS:

002507