HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 136-A-9
PROPERTY RECORDED:
COUNTY: CASWELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: J. L. Hope OWNER: ✓ AGENT: PHONE: 872-9111
ADDRESS: APPLICATION DATE: 2/22/95 DATE EVALUATED: 2/22/95
PROPOSED FACILITY: 3BR House w/ BASEMENT
PROPERTY SIZE: ~4 ACRES.
LOCATION OF SITE: CHIPLEY FORD, TL RIVER RUN, 0.3 MILE ON (L), 550' off ROAD
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY		
1	L 10%	0-48	C	SBK	1:1	FI	.1942 WETNESS CONDITION: S .1943/.1956 SAPROLITE: S .1944 RESTRICTIVE HORIZON: S .1948 PROFILE CLASSIFICATION: PS PROFILE LTAR: 0.35
2	L 8-10	0-54	C	SBK	1:1	FI	.1942 WETNESS CONDITION: S .1943/.1956 SAPROLITE: S .1944 RESTRICTIVE HORIZON: S .1948 PROFILE CLASSIFICATION: PS PROFILE LTAR: 0.35
3							.1942 WETNESS CONDITION: .1943/.1956 SAPROLITE: .1944 RESTRICTIVE HORIZON: .1948 PROFILE CLASSIFICATION: PROFILE LTAR:
4							.1942 WETNESS CONDITION: .1943/.1956 SAPROLITE: .1944 RESTRICTIVE HORIZON: .1948 PROFILE CLASSIFICATION: PROFILE LTAR:
5							.1942 WETNESS CONDITION: .1943/.1956 SAPROLITE: .1944 RESTRICTIVE HORIZON: .1948 PROFILE CLASSIFICATION: PROFILE LTAR:

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 gpd
OTHER FACTORS (.1946): NONE SYSTEM TYPE: CHAMBERED GRAVITY (OWNER'S REQUEST)
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: JOHNNY LEE HOPE, JOHNNY HOPE
COMMENTS:

DRAFT

000714