IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles L. Redmond DATE 25 July 74 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION Shelly Ford Rd - Approx ½ mile on right past Liberty Church Sub division S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 2½ acres

Character & Porosity of Soil Red Clay Loam

Percolation Rate slow

Topography Slope & rise

Depth to Water Table _____

Rock or other impervious formation _____



Plot of System Shelly Ford Rd

Existing System

Size of Tank 1000 ? Gals.

Nitrification Field:

No. of Lines _____

Sq. Ft. _____ Linear Ft. _____

Depth of Stone in Lines _____

Water Supply: Individual ( )

Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Existing System for mobil home installed and not inspected in 1970. Approx 200' of line & approx 300-400 sq ft.

100' of new line install - 5' x 50' - 250 sq ft. Inspected and approved by Sanitarian satisfied with all lines - Inspection requested for all lines

CERTIFICATE OF COMPLETION BY William M. Hanson DATE 25 July 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold