IREDELL COUNTY HEALTH DEPARTMENT

Nelson Brown Bldg.

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Woods DATE May 19, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Clyde Ford Rd on left past Freedy Acres

S. R. No. _____

SUBDIVISION NAME Rowan Acres LOT NO. 5-6-7 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	( )	No	(✓)
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 1 acre


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Slight Slope

Depth to Water Table Low

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Mobile home to be placed in area around driveway, system originally installed in 1976 inspected by E.A. Stevenson, mobile home must be moved off property before house can be occupied.

CERTIFICATE OF COMPLETION BY Andrew E. Caudy DATE 5/19/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold