33630

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

9713

OWNER OR CONTRACTOR Phil McClain DATE 8 31 89 PERMIT NO.

PHONE: Business Home

LOCATION 115 N Snow Creek 2½ mi on left at the Rd

S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House ( ✓ ) Mobile Home ( ) Business ( ) Other

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No ( ✓ )

Auto. Dishwasher Yes ( ✓ ) No ( )

Auto. Wash. Machine Yes ( ✓ ) No ( )

Site Suitable Yes ( ✓ ) No ( )

Lot Area 2.50 AC

Character & Porosity of Soil Apparently suitable


Percolation Rate

Topography Rolling

Depth to Water Table

Rock or other impervious formations Scattered Rock

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 300 Linear Ft. 100

Depth of Stone in Lines 12

Water Supply: Individual ( ✓ )

Public ( )

Installed by Wes Lyerly

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Ottaway

COMMENTS: Use Nearest bedroom to creek

CERTIFICATE OF COMPLETION BY Ottaway DATE 8 31 89

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold