IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wilson Craft DATE 6-5-80 PERMIT NO.

PHONE: Business / Home

LOCATION Shipley Ford Rd. across Yadkin River – Mobile Home on Rt at Barnhill


SUBDIVISION NAME S. R. No.

LOT NO. SECTION OR BLOCK NO. Wade Daniels Property

House ( ) Mobile Home (✓) Business ( ) Other Thos. Sentelle

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Loam	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	2	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Unk	
Lot Area Adequate			Rock or other impervious formations	None	



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Self

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY DATE 6/5/80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy White

OCT. 18, 1989 3:53