IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 38449
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

12101

OWNER OR CONTRACTOR SAM HALL DATE 11/30/90 PERMIT NO. 13G-A-47

PHONE: Business 876-0717 Home

LOCATION US 21 N, TL JENNINGS, TL SNOW CREEK RD, ~ 1 MILE ON (L)

SUBDIVISION NAME S. R. No.

LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2


Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 3 Ac.

Character & Porosity of Soil PS
Percolation Rate .4
Topography 2-4 % LS
Depth to Water Table >4'
Rock or other impervious formations NONE

(✓) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement

TP 11/16/90



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by JAMES HUDDLER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS:

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 11/30/90

EXISTING SYSTEM CHECKED BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold