DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM 4749 03 1519

OWNER: UNITED PROPERTIES APPLICANT: RONALD FANNING
ADDRESS: 6805 MORRISON BLVD, CHAE, NC 28212 APPLICATION DATE: 4-1-02 DATE EVALUATED: 5-3-02
PROPOSED FACILITY: PICNIC SHELTER PROPOSED DESIGN FLOW (.1949): 100 PROPERTY SIZE: 75.41 AC
LOCATION OF SITE: SNOW CREEK RD TO SAKEDACH LANE MAP (2) PROPERTY RECORDED: _____
TO POND 1
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 6%	0-19	GR LS	VFR ~~SEAP~~					PS 0.1
		19-40	ABK SC	FR SEAP					
		40-48	ABK C	FI VS/VP SEXP					
2	L 6%	0-16	GC LS	VFR —					PS 0.1
		16-40	ABK SC	FR SEAP					
		40-48	ABK C	FI VS/VP SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	~~S~~	~~S~~
System Type(s)	II	III
Site LTAR	0.1	0.1

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDSPICK
OTHER(S) PRESENT: RON FANNING, KORY MADISON