DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mac Spain
ADDRESS:
APPLICANT:
APPLICATION DATE:
DATE EVALUATED: 4-22-16
PROPOSED FACILITY:
PROPOSED DESIGN FLOW (.1949):
PROPERTY SIZE:
LOCATION OF SITE: Lot 7 Rocky Creek
PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 10%	0-5	sab brmd L	fr ss,sp I,I					.3+
		5-15	sab rc	fr ss,sp I,I					
		15-28	mod sab RC L	fr ss,sp I,I					
		28-42	mod sab rbm L	fr ss,sp I,I					
2	L 20%	0-6	sab rbmd L	fr I,I					.3+
		6-27	sab RC fr-firm I						
		27-40	sab RC	fr sp I,I					
		40-42	mod sab rbm L	fr ss,sp I,I					
3	L	0-7	sab brmd L	fr I,I					.3
		7-13	sab brm RC	fr ss,sp I,I					
		13-24	sab R CL	fr sp I,I Kaolinitic mixed					
		24-	sab R-brm CL	fr ss,sp I,I Kaolinitic mixed					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT: