DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Max Spear — APPLICANT: _____
ADDRESS: _____ — APPLICATION DATE: _____ — DATE EVALUATED: 9-11-97
PROPOSED FACILITY: _____ — PROPOSED DESIGN FLOW (.1949): 2 bd — PROPERTY SIZE: _____
LOCATION OF SITE: Lot 8 Rocky Creek — PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 0-2%	0-18	gr- brn sl	vfr					.3
		18-35	SAB brn cl	fr ss, p 1.1 few					
		35-48	SAB RC	fi sp 1.1					
2	L 2-4%	0-11	gr-sab brn fr cl						.3
		11-47	SAB R brn cl	fr ss, sp 1.1					
		47-65	SAB R [illegible]	fr ss, p 1.1					
		65+	gr (clay) sl stop	fr					
3	L 4-10%	0-40	SAB w-r cl	fr ss, sp					.3
		40-48+	sl stop	fr vfi					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

9-11-97 Site needs to be cleared up