DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Max Span APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6-18-26
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: 2 acres +/-
LOCATION OF SITE: Lot 12 Rocky Creek PROPERTY RECORDED: no
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 10-12% S-mod	0-24	Sab r-brn	hcmy fr ss,sp-sp					= 34
		24-55	Sab brn-r	cL fr ss,sp					
2	L ~10% S-mod eroded	0-7	gr brn sl fri	fr					= 34
		7-15	Sab r-brn	hcmy fr/fi L sp r-p					
		15-40	Sab r cl	hcmy fr/fi L/I					
		40-60	SL sap	v fr 1:1					
3	L 10-12% S-mod eroded	0-29	sab brn cL	fr sp-ss,sp 1:1					= 34
		29-46	sab r-cL	fr ss,sp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____