COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-22-01

PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____

LOCATION OF SITE: Lot 59 Wiltshire Creek PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

#5 0-35 gr-wk sab brn scl frssp for common manganese
35-60 wk sab gry-brn scl frssp
few gray mottles, few ironstone .34

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
(1)	0-7	wk sab brn scl	fr ssssp					.3 / .4
	7-27	sab r-yel brn fr sl sap	frssssp sspp					
	27-60	wk sab-massive ry-ybrn l/sl l sap	frss-ns sp-np					
(2)	0-7	wk sab brn scl	fr					.3 / .4
	7-20	sab. rol	frssssp sspp					
	20-34	wk f sab yr l mod gran & blky	frssp					
	34-60	massive l/sl l sap	fr ss sp-np					
(3)	0-3	gr brn sl	fr					.35 / .44
	3-17	wk sab ry scl	fr sssp sap					
	17-70	wk f sab massive ry-ybrn sl sap	fr ss-ns np					
(4)	0-8	gr brn sl scl	fr					.3 / .4
	8-25	sab. brn r	fr sssp sspp					
	25-36	wk f sab red sal/l few mod sap	frssp					
	36-58	massive l/sl sap	fr ss sp-np					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Usable Space (.1945)		
System Type(s)		
LTAR		

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____

OTHER(S) PRESENT: _____