ION OF ENVIRONMENTAL HEALTH
SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Wes Spear APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 3bedgpd PROPERTY SIZE: ~20,000sqft
LOCATION OF SITE: Lot 19, Rocky Creek PROPERTY RECORDED: no
WATER SUPPLY: ☐ ~~Private~~ ☐ Public ☑ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☑ ~~Pit~~ ☐ Cut
TYPE OF WASTEWATER: ☑ ~~Sewage~~ ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (1941) 1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L crowned ~10-15%	0-12	gr L/scl	fr					~.3
		12-36	sbk R/yr cl	fr ss sp 1:1					
		36-48	wk sbk R/gy cl/L	fr ss sp mp					
2	L ~10-15%	0-14	bk/y brn SL/scl	fr					~.3
		14-26	sbk y-r C	fr sp 1:1					
		26-41	wk sbk y-r cl	fr ss sp 1:1					
		41-60+	wk sbk gy L	fr					
			w/ mott throughout						
3	L slope ~10-15%	0-13	brn L	fr					~.3
		13-23	brn cl	fr ss sp 1:1					
		23-46	sbk y-r C	fr sp 1:1	Equivocal				
		46-55+	SL sbk	fr					
			w/ some gray mott & manganese						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): ____

EVALUATED BY: ____
OTHER(S) PRESENT: ____