TOWN OF TROUTMAN.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JAMES RUCKER DATE 9-21-90 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Hwy 21 Troutman to T.R. on Byers Rd. - go to end of pavement Left - House back Off rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2.5 Character & Porosity of Soil Clay-Suitable.
Garbage Disposal Unit Yes ( ) No ( ) Percolation Rate 30 min/in ft.
Auto. Dishwasher Yes ( ) No ( ) Topography Level
Auto. Wash. Machine Yes ( ) No ( ) Depth to Water Table 15+
Site Suitable Yes ( ) No ( ) Rock or other impervious formations none observed.
Lot Area Ample

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 220 Lineal Ft. 240
Depth of Stone in Lines 24"
Water Supply: Individual ( )
Public ( )

IMPROVEMENTS PERMIT BY Steve Brown

Installed by Forest Shuford

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 9-21-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold