Paid 175.00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13507 PIN# 4740 41 4251 DATE May 18, 2006

OWNER OR APPLICANT Countryman Bldrs PHONE: Business 704 400 1258 Home

ADDRESS P.O. Box 3421, Mooresville, N.C. 28117

LOCATION 115-2 N TL Flowerhouse Loop TL Carlyle TR Farmdale at end

SUBDIVISION Carlyle Farms BLOCK / SECTION 3 LOT 39 LOT AREA 1.507Ac SITE CLASS. PS DESIGN FLOW 360gpd L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 786 Date 4/10/06

Pump Tank: 1000 Gallons; PT 32 Date 5/7/06

Pump Make: Little Giant Model EN-14CIM Serial No.

Nitrification Field: No Fields 1 Square Feet 723 Linear Feet 241

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions:

* Per Plan Specs

In Line filter required in pump tank.

Comments:/Conditions: 7/21 - Pressure + Down Slope

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Melissa Reed date 5-18-06 Installed by: Countryman Builders

Improvement Permit by: [signature] RS date 5-18-06 Operation Permit by: Wesley Sparks R.S. date 7/21/06

Authorization to Construct by: [signature] RS date 5-18-06 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK