DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Corinthian Bldrs. APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/1/06
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .87
LOCATION OF SITE: Lot 65 CARLYE FARMS PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	2-4% ~in. Rear mid	0-8	MFSbK/cl	FR ss-sP					
		9-24	MFSbK/~c	Fi s-P					.25
		25-37	MMSbK/cl	FR ss-sP					
		38-48	WF~GR/cl	VFR (6 Fi Marl) ss-~sP					.35
2	Rear 2% ~T	0-8	MF GR/l	VFR ss-NP	BR				
		9-25	MF sbk/cl~c	FR ss-sP	R				
		26-48	MF GR/l	VFR ss-sP	WF und R				.35
3	Rear 2-4% ~IRR.	0-9	MF GR/l	VFR ss-NP					
		10-24	MF sbk/c	Fi s-sP					.25
		25-48	MF GR/sbk/scl	FR ss-sP					.30
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	2/90	PPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): Lgt + drainfield
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [signature] MS Reilly