DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ *of* ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Courthouse Bldg. APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/9/06
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L-T (S3) 11-13 R	0-7	MF GR /l	VFR SS-NP	B				.3
		8-20	MOD INCLINED MM SBK /c	FI SS-SP	R				
		21-29	SF INCL SG /cl	FR SS-SP	R				
		30	Rock						
2	S (L53) 11-13 R	0-7	MF GR /l	VFR SS-NP	B				.3 .35
		8-17	MOD INCL MM SBK /c	FR SS-SP	R				
		18-30	MF SBK/cl	FR SS-SP					
		31-49	SF GR LSAP	VFR SS-NP	3R				
3	L ~1150 (L53)	0-6	MF GR l	VFR SS-NP	B				.25 .35
		7-28	LINCL SF SBK c	FI SS-SP	R				
		29-	MVF GR cl	FR SS-SP	R		~4R STREAKS		
4	CVL (S1)	13	MF GR l	VFR SS-SP					.25 .3
		19	~ANG INCL MM SBK	FI SS-SP	R				
		40	MF SBK cl	FR SS-SP	R				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OWNER(S) PRESENT: _____