IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 1777606 ✓

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4740 62 2583

APPLICANT: ELG Investments, LLC APPLICANT ADDRESS: 16108 North Point Rd Huntersville 28078

SITE ADDRESS: 132 Hawks Landing Dr PHONE: 704-578-4951 ALT. PHONE:

SITE DIRECTIONS: Hwy 21 N TL Flowerhouse Ln TL Hawks Landing on right

SUBDIVISION: Hawks Landing SECTION: LOT # 6 LOT AREA: .516 Ac. DESIGN FLOW: 480 gpd L.T.A.R.: .3 gpd/ft²

Septic Tank	1000	(gal)	STB	760	Date	7/27	☒ New System	☐ Repair	☐ Expansion	System Type: I II ⓘ IV V VI	
Pump Tank		(gal)	PT		Date		System Description:	25% Reduction Gravity			
Pump Make		Model			Serial #		Repair System Description:	LP PPBPS			
# Nitrification Fields	1	# Lines	4		Linear Ft:	400	Maintenance Agreement Required:	☐ YES	☒ NO		
Trench Width	36"	Max. Trench Bottom Depth	36"		Gravel Depth	NA	☒ GRAVITY	☐ PRESSURE			

☒ Residence ☐ Business ☐ Other ☒ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

No. Bedrooms: 4 No. Persons: No. Employees:

Water Supply: ☐ Private ☐ Public ☐ Community

Comments / Conditions: 5/13/2014 Renewed Floor plans in Compliance with original plan

~~Do not grade down Septic area or house Slab, otherwise pump may be required~~

INITIAL SITE SKETCH

See Plan From
The Oaks Group, PA
Approved by ICHD

AS BUILT SKETCH

- LAST TWO LINES 8" off House foundation.
- ESSENTIALLY INSTALLED AS PER DRAWING

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 04.15.13 Installed by: Al Backhoe

IMPROVEMENT PERMIT by: Date: 4-10-13 OPERATION PERMIT by: Date: 7/14/14

AUTHORIZATION TO CONSTRUCT by: RS Date: 5/13/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK