IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 177604

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4740 62 3584

APPLICANT: ELG Investments LLC APPLICANT ADDRESS: 16108 North Point Rd Huntersville 28078

SITE ADDRESS: 128 Hawks Landing Dr Troutman 28166 PHONE: 704-578-4951 ALT. PHONE:

SITE DIRECTIONS: 21 N TL Flowerhouse LP TL Hawks Landing on right

SUBDIVISION: Hawks Landing SECTION: LOT # 5 LOT AREA: .571 Ac. DESIGN FLOW: 480 gpd L.T.A.R.: .39gpd/ft²

Septic Tank 1000 (gal) STB Date 8-30
Pump Tank 1000 (gal) PT Date 8-3
Pump Make Model Serial #
Nitrification Fields 1 # Lines 5 Linear Ft: 400
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: 25% Reduction Pump pm
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☐ YES ☒ NO
☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms
☐ Business No. Persons
☐ Other No. Employees
☒ Slab ☐ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply
☒ Private
☐ Public
☐ Community

Comments / Conditions:

INITIAL SITE SKETCH

See Plan from
The Oaks Group, PA
Approved by ICHD

AS BUILT SKETCH

Checked Tanks & Lines
SET 2' PM 2-17-14 12-13-13
BA BA
Alarm + Circuits Checked 3-10-14
AZP

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Kathleen Saunders Date: 4-25-13 Installed by: A-1

IMPROVEMENT PERMIT by: Judy Melville Date: 4-19-13 OPERATION PERMIT by: [signature] Date: 3-10-14

AUTHORIZATION TO CONSTRUCT by: Judy Melville Date: 8-29-13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK