IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 4:00 Mooresville Office (704) 660-3625 PERMIT # 177075 pd $50 2-25-13

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4740 62 5561

APPLICANT: EL 6 Investments LLC APPLICANT ADDRESS:

SITE ADDRESS: Hawks Landing Dr. Troutman 28166 PHONE: 704-578-4951 ALT. PHONE:

SITE DIRECTIONS: 21 N Tr Flower House Tr Hawks Landing on right

SUBDIVISION: Hawks Landing SECTION: LOT # 3 LOT AREA: .557 Ac. DESIGN FLOW: 480 gpd L.T.A.R.: .3 gpd/ft2

Septic Tank 1000 (gal) STB 760 Date 4-3
Pump Tank 1000 (gal) PT 565 Date 7-27
Pump Make ____ Model ____ Serial # ____
Nitrification Fields 1 # Lines 5 Linear Ft: 400
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II (IIIb) IV V VI
System Description: 25 % Reduction pm
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☐ YES ☒ NO
☐ GRAVITY ☒ PRESSURE

☒ Residence ☐ Business ☐ Other ☐ Slab ☐ Basement w/plumbing
No. Bedrooms 4 No. Persons ____ No. Employees ____ ☒ Crawl Space ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions:

INITIAL SITE SKETCH

See Plan from
Kathleens Saunders, LSS
The OAKS Group PA
Approved by ICHD

AS BUILT SKETCH

CHECKED TANKS, LINES, PM 4-10-13
CHECKED PH, ELEC. & ALARM 6-24-13 BA

GOULDS WATER TECHNOLOGY
WE0311M
SUBMERSIBLE PUMP
1/3HP 1/60/115 5.38" 10.7MA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. CONTACT A LOCATOR SER... ...IOR TO ANY EXCAVATION

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: ____ Date: 2/26/13 Installed by: ____

IMPROVEMENT PERMIT by: Judy McNeilly Date: 2-22-13 OPERATION PERMIT by: BA A-1 Date: 6-24-13

AUTHORIZATION TO CONSTRUCT by: Judy McNeilly REHS Date: 2-25-13 Existing System Inspected by: ____ Date: ____

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

1"E 225.34' (T)

108.34'

Found 1.5" Pipe

Found 1.5" Pipe

L1

19.46'

100.00'

S 80°16'02" E 449.4

100.00'

Henry G. & Jo
Deed Book 78
Parcel ID #474

Well

(MSV-PA)

Old Side

Lot 4

50' Repair NF

#2 88' Repair

89' Repair

87' Repair

80'

80'

80'

80'

80'

Lot 3

PM

ST

PT

All Borings, septic lines, house stakes, and wells have been approximately located on this site plan, and have not been located on site by a licensed surveyor.

Lot 2

Berm

25' Corn

35' Setback (Typical)

102.01'

32'03"E 226.16' (T)

Drive

Well

62.83'

10' Septic Supply Line Easement

C22

L47

L46

L45

C30

L16

C31

C5

C4

C3

L23

L24

L8

L25

L17

C32

24" RCP

L3

29.99'

L14(T)

L15(T)

35' Setback

25' Corner Side

C29

C28

Lot 20

6.80'

41'45"W

.79' (T)

289.84'

N88°14'57"W 320.34

Found 1" Pipe

1" = 50'

Approved ICHD
2-22-13

Steve M. & Patricia B. Bail
Deed Book 731 Page 113