IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 1770 73

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4740 62 6468

APPLICANT: ELG Investments APPLICANT ADDRESS: 16108 North Point Rd Huntersville 28078

SITE ADDRESS: 114 Hawks Landing Dr Troutman 28166 PHONE: 704-578-4951 ALT. PHONE:

SITE DIRECTIONS: 21 N TL Flowerhouse TL Hawks Landing on right

SUBDIVISION: Hawks Landing SECTION: LOT # 2 LOT AREA: .56 Ac. DESIGN FLOW: 480 gpd L.T.A.R.: .25 gpd/ft²

Septic Tank	1000	(gal)	STB	760	Date	8-13	☒ New System	☐ Repair	☐ Expansion	System Type: I II III IV V VI	
Pump Tank	1000	(gal)	PT	363	Date	2-20	System Description:	LP PPBPS			
Pump Make			Model		Serial #		Repair System Description:	LP PPBPS			
# Nitrification Fields	1		# Lines	4	Linear Ft:	320	Maintenance Agreement Required:	☒ YES	☐ NO		
Trench Width	24"		Max. Trench Bottom Depth	36"	Gravel Depth	NA		☐ GRAVITY	☒ PRESSURE		

☒ Residence	No. Bedrooms	4	Water Supply	
☐ Business	No. Persons		☒ Private	
☐ Other	No. Employees		☐ Public	
☒ Slab	☐ Crawl Space		☐ Community	
☐ Basement w/plumbing		☐ Basement w/o plumbing		

Comments / Conditions: In-line pump filter required

INITIAL SITE SKETCH

See Plan From
The Oaks Group, PA
Approved by ICHD

NEED MAIN.

AS BUILT SKETCH

HIT NEIGHBORS SEPTIC IN TANK HOLE. TOLD INSTALLER TO CUT LINE OFF & PACK END OF TRENCH SO NO SEWAGE PIECES GOT INTO TANK HOLE. NEIGHBORS SEPTIC IS BEING RELOCATED. 4-18-13

CHECKED LINES & TANKS ↓
CHECKED PM, ELEC & ALARM 6-24-13 BA

GOULDS WATER TECHNOLOGY

WE0511H
SUBMERSIBLE PUMP
1/2HP 1/60/115 3.56" 14.5MA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Mark M Yoro Date: 04-15-13 Installed by:

IMPROVEMENT PERMIT by: Judy Melville Date: 4-15-13 OPERATION PERMIT by: APPROVED Date: MAY 02 2014

AUTHORIZATION TO CONSTRUCT by: Judy Melville Date: 4-15-13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK