IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Lankford DATE 5-16-80 PERMIT NO. 135

PHONE: Business _____ Home _____

LOCATION Hwy 21 N TL 1312 TL 1314 1st house on R

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (X) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Existing System	
Auto. Dishwasher	Yes ( )	No (X)	Percolation Rate		
Auto. Wash. Machine	Yes (X)	No ( )	Topography		
Site Suitable	Yes (X)	No ( )	Depth to Water Table		
			Rock or other impervious formations		

Lot Area 3 Acre

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank Existing Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 16"

Water Supply: Individual (X)
Public ( )

Installed by Sigmon Septic Tank

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Road 1314

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer + David R Hinson DATE 5-16-80

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Lankford DATE Jan. 17, '80 PERMIT NO. 13

PHONE: Business _____ Home _____

LOCATION Hwy 21 N. TL on 1312 TL on 1314 1st house on Rt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3 Ac.

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )
Well next Door

Installed by _____

IMPROVEMENTS PERMIT BY Harold R. Hinson

COMMENTS: Straight-piped washer line to be replumbed to go through septic tank. Drainage ditch over old drain line to be filled in to eliminate seepage of sewage effluent. This permit voids earlier permit written Aug. 8, 1979

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold