12594.

39616

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR KURTIS GOODMAN DATE 4-26-91. PERMIT NO. HF-A-102.

PHONE: Business _____ Home _____

LOCATION Hwy 21 S thru Troutman - T.R. on Barkdale Rd. at Asphalt - 100 yards on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other Machine shop with maximum of 6 employees.

No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes ( ) No (✓)

Site Suitable Yes (✓) No ( )

Lot Area Ample.

Character & Porosity of Soil Prev. Suitable.


Percolation Rate 2-8"/ 10 Min. per ft.

Topography 2-8%

Depth to Water Table 104

Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Lines Ft. 200

Depth of Stone in Lines 12

Water Supply: Individual (✓)

Public ( )

P.S. West Ave.

Installed by Gerald Cadfelter

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-26-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold