IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# Repair PIN# 4740878955 DATE 7/9/05

OWNER OR CONTRACTOR Jonelle Culpepper / Southpark Jewelers PHONE Business 704-528-8055 Home

ADDRESS 149-B Houston Rd. Troutman NC. 28166

LOCATION 115 N - TR Houston Rd, 2ND Building on (D)

SUBDIVISION Park 42 BLOCK / SECTION LOT 7 LOT AREA SITE CLASS PS DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: EXISTING Gallons; STB Date

Pump Tank: EXISTING Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 600 Linear Feet 200

No Lines 2 @ 100' Trench Width 3' Max Trench Bottom Depth 3' Gravel Depth 12"

☐ New System ☒ Repair System Type: I, II, III, IV, V, VI

System Description: PM → Conventional

Repair System Description:

Maintenance Agreement Required: ☐ Yes ☐ No

☐ House/Mod. Home No. Bedrooms

☐ Mobile Home No. Bathrooms


☐ Business No. Employees

☒ Other Business

☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing


Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions:



Comments:/Conditions: Remove old Distribution & Install Pressure Manifold in Protection Box

Orange valve is to stay closed until area is finished up.



Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Tim Bagwell date 7/11/05 Installed by: Heather Moore

Improvement Permit by: Wesley Sparks RS. date 7/9/05 Operation Permit by: Wesley Sparks RS date 7/12/05

Authorization to Construct by: Wesley Sparks RS. date 7/9/05 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK