IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David Sherrill DATE 5-7-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Trenton. 21 S. To on Rd 1001 Mitchell Rd. 5th Lane on left before Dotsons Bapt. Ch. S. R. No 1001


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1 Acre

Character & Porosity of Soil CTC
Percolation Rate Good
Topography 6-10% Slope to Back
Depth to Water Table sink
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by ?
No one at site at time of Insp.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Stone to be added to drainfield at distribution box before covering

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 5/9/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold