IREDELL COUNTY HEALTH DEPARTMENT

[redacted]4-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONS[redacted]ATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 149702 PIN# 4764 09 3238 DATE 5-2-08

OWNER OR APPLICANT Ostwalt Amity Baptist Church PHONE Business 704 528-1027 Home

ADDRESS 198 Ostwalt Amity Rd Troutman, NC 28166

LOCATION US 21/Hwy 115 TR Ostwalt Amity Rd, Church will be on right

SUBDIVISION BLOCK / SECTION LOT LOT AREA 6.76 Acre SITE CLASS. PS DESIGN FLOW 700gpd L.T.A.R. .275

Grease trap 1250gal

Septic Tank: 2000gal Gallons: STB Date

Pump Tank: 2000gal Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 2460' Linear Feet 820'

No Lines 5@164' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: Pump PM -25% Reduction

Repair System Description: Pump - Panel Block

Maintenance Agreement Required: ☐ Yes ☒ No Not Initially

☐ Gravity ☒ Pressure

☐ House/Mod. Home No. Bedrooms

☐ Mobile Home No. Persons

☐ Business No. Employees

☒ Other Church Family Life Center

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Initial Site evaluation and System design performed by SAME and GV Grantt Assoc.
* Install 1250gal Grease trap

Comments/Conditions: Note: See attached Pump tank design
Must keep Septic System 100 Ft From Well

INITIAL SITE SKETCH

See Attached Approved Plan by GV Grantt & Assoc.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Brad Morris date 9-8-08 Installed by:

Improvement Permit by: [signature] date 5/2/08 Operation Permit by: date

Authorization to Construct by: [signature] date Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK