VISION OF ENVIRONMENTAL HEALTH:
I-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

NER: Jean Jones APPLICANT: _____
DDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 12-9-00
OPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
CATION OF SITE: Eastern Loop Rd PROPERTY RECORDED: _____
ATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
ALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut PH #5 & #6 on Tank
PE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
4% ±	0-7	gr fsa l	fr					I.5
	7-21	sm b pcpt fsa	fr-ssp	tawny brown mottles				.3
	21-48	mk fsab	fr-ssp					
				tawny brown				
	0-6	gr fsa l						(1)
	6-14	sbk fsa l	fr					I.P
	14-44	mk sab	fr					.125
	0-5	wk sab fsa l	fr					P.S
	5-23	sab pcpt	fr					.3
	23-47	mk sap gr fsa l	fr					
	0-5	gr fsa l						
	5-24	mk sab fsa l	fr					5.25
	24-48	sbk fsa l	fr					.3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ilable Space (.1945)		
tem Type(s)		
LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____