DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jim Jones OWNER/AGENT/PHONE
ADDRESS: APPLICATION DATE: DATE EVALUATED: 3-22-94
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE:
LOCATION OF SITE: Wagner Heights Lot # 22.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	1945 LANDSCP POS / SLOPE %	HORIZON DEPTH (in)	1945 SOIL TEXTURE	1945 STRUCTURE	1945 MOTTLES / SOIL WETNESS	
1	4-6% L	0-4"	sil	gr	1:1 / vfr	1945 WETNESS CONDITION - P.S
		4-48"	c	sbk	1:1 / fr	1945/1956 SAPROLITE - NA
						1944 RESTRICTIVE HORIZON - NA
						1945 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .35
2	4-6% L	0"-5"	c	gr	1:1 / vfr	1945 WETNESS CONDITION - P.S.
		5"-42"	c	sbk	1:1 / fr	1945/1956 SAPROLITE - 42"-↑
		42"-↑	Saprolite			1944 RESTRICTIVE HORIZON - NA
						1945 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .35
3	3-5% L	0"-7"	c	gr	1:1 / vfr	1945 WETNESS CONDITION - P.S.
		7"-48"	c	sbk	1:1 / fr	1945/1956 SAPROLITE - NA
						1944 RESTRICTIVE HORIZON - NA
						1945 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .35
4	3-5% L	0"-6"	c	gr	1:1 / vfr	1945 WETNESS CONDITION - P.S.
		6"-44"	c	sbk	1:1 / fr	1945/1956 SAPROLITE - 44"-↑
		44"-↑	saprolite			1944 RESTRICTIVE HORIZON - NA
						1945 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .35
5						1945 WETNESS CONDITION -
						1945/1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (1945): P.S. SITE CLASSIFICATION (1945): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(1945): SYSTEM TYPE: Conventional, gravity fed.
EVALUATED BY: Mitchell & Dennis OTHER(S) PRESENT: Install interceptor drain. J.C. Moore, Jim Jones.
COMMENTS:
100% Repair pump to PPBPS.

DRAFT

0012841