IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Milton H Blond, Jr. DATE 6/11/75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 215, T.L. on 2366, T.L. on 2371, white asbestos house across from Troutman Baptist Ch. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay loam	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	good	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	slope to front	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10ft.	
			Rock or other impervious formations	none observed	

Lot Area 200 X 110 approx



Plot of System

Size of Tank 1,000 Gals.

Nitrification Field:
No. of Lines —
Sq. Ft. 525 Linear Ft. 225
Depth of Stone in Lines —

Water Supply: Individual ( )
Public ( )

Installed by Hoke

IMPROVEMENTS PERMIT BY _____

COMMENTS: An addition is planned for the house. System should function properly under normal usage

CERTIFICATE OF COMPLETION BY Andrew E. Canupp DATE 6/11/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold